

~~~~~ **PROJECT NOTE** ~~~~~

ARCHITECT OF RECORD/ENGINEER OF RECORD IS RESPONSIBLE FOR REVIEWING THIS SPECIFICATION SECTION IN DETAIL FOR COORDINATION WITH THE PROJECT SCOPE OF WORK.

ALL "PROJECT NOTE" TEXT IS TO BE REMOVED FOLLOWING REVIEW OF THE CONTENT OF EACH NOTE BY THE ARCHITECT OF RECORD/ENGINEER OF RECORD.

EDIT THE DOCUMENT FOOTER TO INCLUDE THE PROJECT NAME AND NUMBER.

EDIT THE DOCUMENT HEADER TO INDICATE THE ARCHITECT OF RECORD PROJECT ISSUE" DATE. THE "CPS CONTROL" DATE SHOULD NOT BE EDITED.

ANY MODIFICATIONS TO THE TECHNICAL STANDARDS IN THIS SECTION - INCLUDING THE REMOVAL OR ADDITION OF MANUFACTURERS - MUST BE APPROVED BY CPS. REQUESTS FOR MODIFICATION ARE TO BE SUBMITTED TO THE DESIGN MANAGER DURING THE DESIGN PHASE FOR REVIEW AND APPROVAL.

~~~ **END OF PROJECT NOTE** ~~~

SECTION 27 51 16
PUBLIC ADDRESS SYSTEMS

~~~~~ **PROJECT NOTE** ~~~~~

COORDINATE THIS SPECIFICATION WITH 27 51 26 ASSISTIVE LISTENING DEVICE SYSTEMS SPECIFICATION. 27 51 26 ASSISTIVE LISTENING DEVICE SYSTEMS SPECIFICATION IS REQUIRED TO BE ISSUED WITH 27 51 16 PUBLIC ADDRESS SYSTEMS AND/OR 27 51 16.01 OUTDOOR PUBLIC ADDRESS SYSTEMS SPECIFICATIONS.

THIS SPECIFICATION HAS BEEN UPDATED TO REFLECT THE DIGITAL PUBLIC ADDRESS SYSTEM AND AS SUCH NO ANALOG DEVICES AND EQUIPMENT SHALL BE SPECIFIED. WHERE EXISTING ANALOG SYSTEM IS FUNCTIONAL, THE ANALOG SYSTEM WILL INTERFACE SEAMLESSLY WITH THE NEW DIGITAL EQUIPMENT BEING ADDED.

~~~ **END OF PROJECT NOTE** ~~~

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Amplifier and control equipment.
- B. Input equipment.
- C. Reproducer equipment.
- D. Sound system cable.
- E. Accessories.

1.02 DEFINITIONS

- A. Refer to Section 27 05 03 - Communications General Requirements for definitions.

1.03 REFERENCE STANDARDS

- A. City of Chicago Building Code - Municipal Code of Chicago, Title 14B, Building Code 2019.
- B. Chicago Electrical Code - Municipal Code of the City of Chicago, Building/Electrical Code Requirements 2018.

| | | |
|----------------------------------|--------------|------------------------|
| NAME OF SCHOOL
PROJECT NUMBER | 27 51 16 - 1 | PUBLIC ADDRESS SYSTEMS |
|----------------------------------|--------------|------------------------|

- C. UL 50 - Enclosures for Electrical Equipment, Non-Environmental Considerations Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

A. Coordination

1. Coordinate layout and installation of system components and suspension system with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, fire-suppression system, and partition assemblies.

1.05 SUBMITTALS

- A. Shop Drawings: Indicate electrical characteristics and connection requirements. Indicate layout of equipment mounted in racks and cabinets, component interconnecting wiring, and wiring diagrams of field wiring to speakers and remote input devices.

1. Equipment Details: Detail equipment assemblies and indicate dimensions, weights, required clearances, method of field assembly, components, and location of each field connection.

~~~~~ **PROJECT NOTE** ~~~~~

DELETE SUBPARAGRAPHS AND ASSOCIATED SUBPARAGRAPHS BELOW IF NOT REQUIRED.

~~~ **END OF PROJECT NOTE** ~~~

2. Console layouts.
 3. Control panels.
 4. Rack arrangements.
 5. Wiring Diagrams: Power, signal, and control wiring. Include the following:
 - a. Identify terminals to facilitate installation, operation, and maintenance.
 - b. Single-line diagram showing interconnection of components.
 - c. Cabling diagram showing cable routing.
- B. Calculations: For sizing backup battery.

~~~~~ **PROJECT NOTE** ~~~~~

RETAIN PARAGRAPH AND SUBPARAGRAPH BELOW IF DRAWINGS DO NOT INCLUDE DETAILED PLANS OR IF PROJECT INVOLVES UNUSUAL COORDINATION REQUIREMENTS.

~~~ **END OF PROJECT NOTE** ~~~

- C. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, based on input from installers of the items involved:

~~~~~ **PROJECT NOTE** ~~~~~

EDIT SUBPARAGRAPH BELOW TO SUIT PROJECT.

~~~ **END OF PROJECT NOTE** ~~~

1. Ceiling-mounted items including lighting fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.
2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.

3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.

~~~~~ **PROJECT NOTE** ~~~~~

ADJUST LIST BELOW TO SUIT PROJECT.

~~~~ **END OF PROJECT NOTE** ~~~~

- D. Product Data: Provide data showing electrical characteristics and connection requirements for each component, including: .
 1. Preamplifiers.
 2. Power amplifiers.
 3. Microphone.
 4. Compressor limiter.
 5. Equipment cabinet and rack.
 6. Monitor panel.
 7. Loudspeakers.
 8. Microphone and headphone outlets.
 9. Power sequencer
- E. Qualification Data: For Installer.
- F. Field quality-control test reports.
- G. Operation Data: Include instructions for adjusting, operating, and extending the system.
- H. Maintenance Data: Include repair procedures and spare parts documentation.

1.06 QUALITY ASSURANCE

- A. Installer Qualifications: Authorized installer of specified manufacturer with service facilities within fifty (50) miles of Project.
 1. Manufacturer's authorized representative who is trained and approved for installation of units required for this Project.
 2. Installer must have been in business a minimum of five (5) years and have a minimum of five (5) similar installations.
- B. Source Limitations: Obtain public address and music equipment through a single source authorized by manufacturer to distribute each product.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in ANSI/IEEE 802.7, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- D. Comply with City of Chicago Building Code.
- E. Comply with UL 50.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Do not install electronic components until major construction work in the area is complete. Do not install in areas where dust or moisture can contaminate the working parts or where finish can be marred by construction work.
- B. Stage materials in a secure area of the project site until installation. Materials and items shall be placed so that they are protected from damage and deterioration.

PART 2 PRODUCTS

2.01 SYSTEM DESIGN

- A. Public address system for voice and music.
- B. The system will provide for the amplified distribution of program material to the outlined speaker systems. Program origination will be from system sources and/or other sources outlined in this Section.

| | | |
|----------------------------------|--------------|------------------------|
| NAME OF SCHOOL
PROJECT NUMBER | 27 51 16 - 3 | PUBLIC ADDRESS SYSTEMS |
|----------------------------------|--------------|------------------------|

- C. The systems to be installed shall include the following:
 - 1. Main/Auxiliary Gymnasium Sound System - Capable of one common or three independent channels.
 - 2. Multipurpose Room Gymnasium Sound System - Capable of one common or three independent channels.
 - 3. Natatorium Sound System - Capable of one common or three independent channels.
 - 4. Cafeteria Sound System.

2.02 FUNCTIONAL DESCRIPTION OF SYSTEM

- A. System Functions: Include the following:
 - 1. Selectively connecting separate zones to different signal channels.
 - 2. Selectively amplifying sound among various microphone outlets and other inputs.
 - 3. Communicating simultaneously to all zones regardless of zone or channel switch settings.
 - 4. Reproducing high-quality sound that is free of noise and distortion at all loudspeakers at all times during equipment operation including standby mode with inputs off; and output free of non-uniform coverage of amplified sound.

2.03 EQUIPMENT AND MATERIALS

- A. Coordinate features to form an integrated system. Match components and interconnections for optimum performance of specified functions.
- B. Equipment: Modular type using solid-state components, fully rated for continuous duty, unless otherwise indicated. Select equipment for normal operation on input power usually supplied at 110 to 130 V, 60 Hz.
- C. Waterproof Equipment: Listed and labeled for duty outdoors or in damp locations.

2.04 AMPLIFICATION AND CONTROL EQUIPMENT

- A. Gymnasium, Multipurpose Room 3-Channel Local Sound System:
 - 1. Equipment Cabinets: 3-section wall mounted with key locking front doors
 - a. Atlas/IED 300 Series
 - b. Lowell L260 Series
 - c. Middle Atlantic DWR Series
 - 2. Master On-Off Panels: 20 amp rack mount panel with a minimum of eight (8) outlets.
 - a. Atlas/IED
 - b. Lowell
 - c. Middle Atlantic
 - 3. Mixers: Digital signal processor. Provide for each system at minimum inputs for (2) wireless microphones, (one handheld and one Lavalier), one (1) wired input and one (1) AUX input.
 - a. Biamp
 - b. BSS
 - c. Shure
 - 4. Amplifiers: 4 channel, with Power Amplifier (provide system with 3 channels and 1 spare backup channel of amplification, 1200 watts per channel at 8 ohms and at 70 volt RMS.).
 - a. Crown
 - b. QSC
 - c. Yamaha
 - 5. Equalization Panels: Provide each system with a separate channel of equalization. Equalization shall be provided as part of the digital signal processing
 - 6. Control Modules: Provide the quantity and type module for each system input and include override electronics for central school intercom system priority.

7. Surge Protection: Provide a surge protector to protect the electronics for each system.
 - a. Exide
 - b. Furman
 - c. Tripp Lite
 8. Cabinet Hardware: Provide matching filler panels for all unused spaces as well as engraved labels for each control and any hardware connectors, etc., for a complete and operating system.
- B. Cafeteria Local Sound System:
1. Equipment Cabinets: 3-section wall mounted with key locking front doors
 - a. Atlas/IED 300 Series
 - b. Lowell L260 Series
 - c. Middle Atlantic DWR Series
 2. Master On-Off Panels: 20 amp rack mount panel with a minimum of eight (8) outlets.
 - a. Atlas/IED
 - b. Lowell
 - c. Middle Atlantic
 3. Mixers: Digital signal processor. Provide for each system at minimum inputs for (2) wireless microphones, (one handheld and one Lavalier), one (1) wired input and one (1) AUX input.
 - a. Biamp
 - b. BSS
 - c. Shure
 4. Amplifiers: 2 channel, with Power Amplifier (provide system with 2 channels of amplification, 600 watts per channel at 8 ohms and at 70 volt RMS.).
 - a. Crown
 - b. QSC
 - c. Yamaha
 5. Equalization Panels: Provide system with equalization. Equalization shall be provided as part of the digital signal processing.
 6. Control Modules: Provide the quantity and type module for each system input and include override electronics for central school intercom system priority.
 7. Surge Protection: Provide a surge protector to protect the electronics for each system.
 - a. Exide
 - b. Furman
 - c. Tripp Lite
 8. Cabinet Hardware: Provide matching filler panels for all unused spaces as well as engraved labels for each control and any hardware connectors, etc., for a complete and operating system.

2.05 PROGRAM SOURCES FOR EACH SYSTEM

- A. CD Unit: Denon/Marantz CD Bluetooth or Tascam Equivalent - rack mounted.
- B. Digital Tuner: Precision Electronics T-115 or TOA DT Series equivalent - rack mounted.

2.06 SPEAKER SYSTEMS

- A. Gymnasium Speaker Systems: Full range systems with recommended hanging hardware and with custom face plates. Provide 70 volt transformers on each speaker.
 1. Altec
 2. Community
 3. JBL

- B. Cafeteria Speaker Systems: 8 inch round coaxial speakers with 70 volt transformers with round white speaker grilles and recessed back-boxes and supports.
 - 1. Community
 - 2. JBL
 - 3. Rauland
- C. Natatorium Speaker System: Underwater type speakers for in pool use. Marine/harsh environment type speakers for pool area. Full range system with recommended hanging hardware and institutional face plates. Provide transformers on speakers as required.
 - 1. Lubbell Labs Inc

2.07 WIRE AND CABLE

- A. Speaker Cable: 2 conductor, 16gauge in overall PVC jacket.
 - 1. Belden
 - 2. C2G
 - 3. West Penn
- B. Microphone Cable: 2 conductor, 22 gauge, shielded in overall PVC jacket
 - 1. Belden
 - 2. C2G
 - 3. West Penn.

2.08 ACCESSORIES

- A. Provide the following system accessories to be used with the Gymnasiums, Natatorium, Multipurpose Room and Cafeteria Sound Systems:
 - 1. Wired Microphones: Provide 3 Dynamic and Cardioid.
 - a. AKG
 - b. Audio-Technica
 - c. Shure
 - 2. Microphone Cords: Provide 2 - 25 foot and 2 - 50 foot microphone cords.
 - a. Conquest
 - b. Horizon
 - c. Shure
 - 3. Microphone Stands: Provide 3 Floor and 3 Desk Stands.
 - a. Atlas/IED
 - b. Rauland
 - c. Shure
 - 4. Wireless Microphones: Provide for each system on (1) Lavalier and one (1) handheld wireless microphone.
 - a. AKG
 - b. Audio-Technica
 - c. Shure

2.09 PATHWAYS

- A. Conduit and Boxes: Comply with requirements in Sections 26 05 33.13 - Conduit for Electrical Systems, 26 05 33.16 - Boxes for Electrical Systems, and 26 05 33.23 - Surface Raceways for Electrical Systems. Flexible metal conduit shall not be used.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Wiring Method: Install wiring in raceways except within consoles, desks, and counters. Conceal raceways except in unfinished spaces.

- C. Wiring within Enclosures: Bundle, lace, and train conductors to terminal points with no excess. Use lacing bars in cabinets.
- D. Control-Circuit Wiring: Install number and size of conductors as recommended by system manufacturer for control functions indicated.
- E. Separation of Wires: Separate speaker-microphone, line-level, speaker-level, and power wiring runs. Install in separate raceways or, where exposed or in same enclosure, separate conductors at least 12 inches - for speaker microphones and adjacent parallel power and telephone wiring. Separate other intercommunication equipment conductors as recommended by equipment manufacturer.
- F. Splices, Taps, and Terminations: Arrange on numbered terminal strips in junction, pull, and outlet boxes; terminal cabinets; and equipment enclosures.
- G. Match input and output impedances and signal levels at signal interfaces. Provide matching networks where required.
- H. Identification of Conductors and Cables: Color-code conductors and apply wire and cable marking tape to designate wires and cables so they identify media in coordination with system wiring diagrams.
- I. Wall-Mounting Outlets: Flush mounted.
- J. Floor-Mounting Outlets: Conceal in floor and install cable nozzles through outlet covers. Secure outlet covers in place. Trim with carpet in carpeted areas.
- K. Conductor Sizing: Unless otherwise indicated, size speaker circuit conductors from racks to loudspeaker outlets not smaller than No. 18 AWG and conductors from microphone receptacles to amplifiers not smaller than No. 22 AWG.
- L. Weatherproof Equipment: For units that are mounted outdoors, in damp locations, or where exposed to weather, install consistent with requirements of weatherproof rating.
- M. Speaker-Line Matching Transformer Connections: Make initial connections using tap settings indicated on Drawings.
- N. Connect wiring according to Section 26 27 26 - Wiring Devices.
- O. Make cable shields continuous at splices and connect speaker circuit shield to equipment ground only at amplifier.
- P. Support cables above accessible ceilings to keep them from resting on ceiling tiles. Use spring metal clips or plastic cable ties to support cables from structure for ceiling suspension system. Include bridle rings or drive rings.
- Q. Use suitable cable fittings and connectors.
- R. Connect reproducers to amplifier with matching transformers.
- S. Ground and bond equipment and circuits in accordance with Section 26 05 26 - Grounding and Bonding for Electrical Systems.
 - 1. Ground cable shields and equipment to eliminate shock hazard and to minimize ground loops, common-mode returns, noise pickup, cross talk, and other impairments.
 - a. Do not ground microphone line shields, except at microphone frame and at console input connectors.
 - b. Ground other shields of two-conductor cables only at one (1) end, as required. Terminate "floating" ends with wedge-on collars, plastic tape, or heat-shrinkable tubing.
 - c. Maintain continuity of shields at all connecting points.
 - 2. Signal Ground Terminal: Locate at main equipment cabinet. Isolate from power system and equipment grounding. Connect all audio grounds in an equipment rack to a common point.

3.02 FIELD QUALITY CONTROL

- A. Perform the following field tests and inspections and prepare test reports:

| | | |
|----------------------------------|--------------|------------------------|
| NAME OF SCHOOL
PROJECT NUMBER | 27 51 16 - 7 | PUBLIC ADDRESS SYSTEMS |
|----------------------------------|--------------|------------------------|

1. Schedule tests with at least seven days' advance notice of test performance.
2. After installing public address and music equipment and after electrical circuitry has been energized, test for compliance with requirements.
3. Operational Test: Perform tests that include originating program and page messages at microphone outlets, preamplifier program inputs, and other inputs. Verify proper routing and volume levels and that system is free of noise and distortion.
4. Signal-to-Noise Ratio Test: Measure signal-to-noise ratio of complete system at normal gain settings as follows:
 - a. Disconnect microphone at connector or jack closest to it and replace it in the circuit with a signal generator using a 1000-Hz signal. Replace all other microphones at corresponding connectors with dummy loads, each equal in impedance to microphone it replaces. Measure signal-to-noise ratio.
 - b. Repeat test for each separately controlled zone of loudspeakers.
 - c. Minimum acceptance ratio is 50 dB.
5. Distortion Test: Measure distortion at normal gain settings and rated power. Feed signals at frequencies of 50, 200, 400, 1000, 3000, 8000, and 12,000 Hz into each preamplifier channel. For each frequency, measure distortion in the paging and all-call amplifier outputs. Maximum acceptable distortion at any frequency is 3 percent total harmonics.
6. Acoustic Coverage Test: Feed pink noise into system using octaves centered at 500 and 4000 Hz. Use sound-level meter with octave-band filters to measure level at five locations in each zone. For spaces with seated audiences, maximum permissible variation in level is plus or minus 2 dB. In addition, the levels between locations in the same zone and between locations in adjacent zones must not vary more than plus or minus 3 dB.
7. Power Output Test: Measure electrical power output of each power amplifier at normal gain settings of 50, 1000, and 12,000 Hz. Maximum variation in power output at these frequencies must not exceed plus or minus 1 dB.
8. Signal Ground Test: Measure and report ground resistance at public address equipment signal ground. Comply with testing requirements specified in Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- B. Retesting: Correct deficiencies, revising tap settings of speaker-line matching transformers where necessary to optimize volume and uniformity of sound levels, and retest. Prepare a written record of tests.
- C. Inspection: Verify that units and controls are properly labeled and interconnecting wires and terminals are identified. Prepare a list of final tap settings of paging speaker-line matching transformers.

~~~~~ **PROJECT NOTE** ~~~~~

DELETE THIS ARTICLE IF BOARD CONTRACTS SEPARATELY FOR THIS SERVICE. CONSIDER INCLUDING A PROVISION FOR SUBMITTING A CONTINUING MAINTENANCE AGREEMENT PROPOSAL.

~~~ **END OF PROJECT NOTE** ~~~

3.03 ADJUSTING

- A. On-Site Assistance: Engage a factory-authorized service representative to provide on-site assistance in adjusting sound levels, resetting transformer taps, and adjusting controls to meet occupancy conditions.

| | | |
|----------------------------------|--------------|------------------------|
| NAME OF SCHOOL
PROJECT NUMBER | 27 51 16 - 8 | PUBLIC ADDRESS SYSTEMS |
|----------------------------------|--------------|------------------------|

- B. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting system to suit actual occupied conditions. Provide up to two visits to site outside normal occupancy hours for this purpose, without additional cost.

3.04 CLEANING

- A. On completion of installation inspect exposed finishes. Remove burrs, dirt, paint spots, and construction debris. Repair damaged finish(es), including chips, scratches, and abrasions.
- B. All equipment, hardware and finishes shall be cleaned prior to final acceptance. Unless otherwise indicated, clean shall mean free of dust, dirt, mud, debris, oil, grease, residues, and contamination.
- C. Protect equipment and installations and maintain conditions to ensure that coatings, finishes, and cabinets are without damage or deterioration at time of Substantial Completion. Protect conduit and wireway openings against the entrance of foreign matter by means of plugs or caps. Cover fixtures, materials, equipment and devices furnished or installed under this Section or otherwise protect against damage, both before and after installation. Hardware, materials, equipment, or devices damaged prior to final acceptance of the work shall be restored to their original condition or replaced.
- D. During the course of installation work, provide for on-going proper disposal of all debris, including but not limited to: equipment packaging and shipping materials, shipping pallets, empty cable reels/boxes, cable cuttings, etc. The Contractor shall, at all times, keep the site free from accumulations of waste material or rubbish caused by its employees or work. Remove all crates, cartons, and other waste materials or trash from the working areas at the end of each working day. Flammable waste material must be removed from the working areas at the time of generation. All rubbish and debris, combustible or not, shall be discarded in covered metal containers daily and removed from the premises at least weekly and legally disposed of.

3.05 CONTRACTOR STARTUP

- A. Startup Service: Verify that electrical wiring installation complies with manufacturer's submittal and installation requirements. Complete installation and startup checks according to manufacturer's written instructions.

3.06 CLOSEOUT ACTIVITIES

- A. See Section 01 79 00 - Demonstration and Training, for additional requirements.
 - 1. Schedule training with at least seven days advanced notice.
- B. Demonstration: Demonstrate operation of system to Board's personnel.
 - 1. Use operation and maintenance data as reference during demonstration.
 - 2. Briefly describe function, operation, and maintenance of each component.
- C. Training: Train Board's personnel on operation and maintenance of system.
 - 1. Train Board's maintenance personnel to adjust, operate, and maintain public address and music equipment.
 - 2. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
 - 3. Provide minimum of four hours of training.

END OF SECTION

| | | |
|----------------------------------|--------------|------------------------|
| NAME OF SCHOOL
PROJECT NUMBER | 27 51 16 - 9 | PUBLIC ADDRESS SYSTEMS |
|----------------------------------|--------------|------------------------|