

POWER SYMBOLS

WALL MOUNTED	FLOOR BOX	POKE-THROUGH	CEILING MOUNTED	
				DUPLEX RECEPTACLE
				QUAD RECEPTACLE
				SINGLE RECEPTACLE
				ISOLATED GROUND DUPLEX RECEPTACLE (ORANGE)
				ISOLATED GROUND QUAD RECEPTACLE (ORANGE)
				COMBINATION IG DUPLEX RECEPTACLE (ORANGE), DUPLEX RECEPTACLE AND TELEPHONE/ DATA SYSTEMS OUTLET
				TECHNOLOGY DUPLEX RECEPTACLE (GREY)
				TECHNOLOGY QUAD RECEPTACLE (GREY)
				COMBINATION TECHNOLOGY DUPLEX RECEPTACLE (GREY), DUPLEX RECEPTACLE AND TELEPHONE/ DATA SYSTEMS OUTLET
				SPECIAL RECEPTACLE – REFER TO SPECIAL RECEPTACLE SCHEDULE
				JUNCTION BOX WITH FLEXIBLE CONDUIT AND FINAL EQUIPMENT OR FURNITURE SYSTEM POWER CONNECTION
WP XX ADJACENT LETTERS IN THE SYMBOLS ABOVE INDICATE THE FOLLOWING: "CR" CHILD RESISTANT (SAFETY TYPE) "CS" CHARGING STATION "E" RECEPTACLE FED BY EMERGENCY CIRCUIT "EP" EXPLOSION PROOF "EWC" RECEPTACLE SERVES ELECTRIC WATER COOLER "GFI" GROUND FAULT CIRCUIT INTERRUPTER "IG" ISOLATED GROUND "TVS" TRANSIENT VOLTAGE SURGE SUPPRESSION "WP" WATERPROOF COVER "XX" CIRCUIT NUMBER "S" SAFETY TYPE "T" TECHNOLOGY LOADS				
	DUPLEX RECEPTACLE – MOUNTING HEIGHT AS NOTED ABOVE COUNTER			
	CLOCK OUTLET AND CLOCK FOR INTEGRATED CLOCK SYSTEM.			
	DUAL FACED CLOCK OUTLET AND CLOCK FOR INTEGRATED CLOCK SYSTEM.			



CHICAGO PUBLIC SCHOOLS CAPITAL IMPROVEMENT PROGRAM INFORMATION TECHNOLOGY SERVICES INFRASTRUCTURE STANDARDS POWER SYMBOLS

DESIGNED	CPS
DRAWN	CPS
CHECKED	CPS
APPROVED	CPS
NO.	DATE
REVISION	BY

PROJECT NUMBER	SCALE	DATE	SHEET NO.
	NONE	06/01/24	ED.002