


BENDING RADIUS FOR FIBER OPTIC CABLES AND
CAT 6A AS PER MANUFACTURER'S SPECIFICATIONS
AND TIA/EIA STANDARDS

METAL RACEWAY TO CONNECT ROOM ENTRANCE



NOTE:

- IF USING EXISTING NON-FIBER RATING FITTINGS
USE APPROPRIATE FIBER INSERT.
- ALL NEW FITTINGS SHOULD BE FIBER RATED SURFACE MOUNTED
METAL RACEWAY.



CHICAGO PUBLIC SCHOOLS
CAPITAL IMPROVEMENT PROGRAM
INFORMATION TECHNOLOGY SERVICES
INFRASTRUCTURE STANDARDS

CONDUIT ROOM ENTRANCE
CAPITAL IMPROVEMENT PROGRAM

DESIGNED CPS	PROJECT NUMBER	SCALE NONE	DATE 09/15/25	SHEET NO. ED.854
DRAWN CPS				
CHECKED CPS				
APPROVED CPS				
NO.	DATE	REVISION	BY	